

DMR Copy of Record

Permit

Permit #:

MAR053712

Major:

No

Permittee:

ReEnergy Holdings

Permittee Address:

101 Gerard Street
Roxbury, MA 02119

Facility:

REENERGY ROXBURY, INC.

Facility Location:

101 GERARD STREET
ROXBURY, MA 02119

Permitted Feature:

001
External Outfall

Discharge:

001-LK
Lead: Water Hardness 250+ mg/l

Report Dates & Status

Monitoring Period:

From 04/01/18 to 06/30/18

DMR Due Date:

08/31/18

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:

Last Name:

Title:

Telephone:

No Data Indicator (NODI)

Form NODI:

--

Parameter	Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
01051	Lead, total [as Pb]	1 - Effluent Gross	0	--	Sample									=	0.091	19 - mg/L		01/90 - Quarterly	GR - GRAB
					Permit Req.									<=	.262 MAXIMUM	19 - mg/L	0	01/90 - Quarterly	GR - GRAB
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Total Hardness was measured at 220 mg/L. Therefore the benchmark for Lead is 0.213 mg/L. The total Lead concentration of 0.091 mg/L is below that limit.

Attachments

Name	Type	Size
RoxburyMA_Weather_04-16-18.pdf	pdf	839108

Report Last Saved By

ReEnergy Holdings

User:

FBRUNEAU

Name:

Frederic Bruneau

E-Mail:

fbruneau@reenergyholdings.com

Date/Time:

2018-05-31 09:55 (Time Zone: -04:00)

Report Last Signed By

User:

FBRUNEAU

Name:

Frederic Bruneau

E-Mail:

fbruneau@reenergyholdings.com

Date/Time:

2018-05-31 10:19 (Time Zone: -04:00)